
3280HUD- Log #84
(3280.813(b))

Final Action:

Submitter: John Walters, Cavco Industries

Recommendation: Revise required label from 3280.813(b) to read the same as requirement in 2005 NEC article 550.20(B):

~~This Connection is for Air Conditioning Equipment Rated at Not More Than _____ Amperes, at _____ Volts, 60 Hertz. A disconnect shall be located within sight of the appliance.~~

THIS CONNECTION IS FOR HEATING
AND/OR AIR CONDITIONING EQUIPMENT.
THE BRANCH CIRCUIT IS RATED AT NOT
MORE THAN _____ AMPERES. AT
_____ VOLTS, 60 HERTZ
A DISCONNECTING MEANS SHALL BE LOCATED
WITHIN SIGHT OF THE EQUIPMENT.

Substantiation: The stated outlet is for heating and/or air conditioning equipment so label should reflect the same. Both 3280 and the NEC have the same requirement other than the wording for the label.

This will enable manufacturers that build HUD and Factory Built Homes to use the same label.